

ECODESIGN INFORMATION

According to Regulation EU No 327/2011 of the European Commission, implementing Directive 2009/125/CE of European Parliament
Apply to fans

SODECA, S.L.U.

www.sodeca.com

ERP: Performance at the best efficiency point (BEP)

MC	Measurement category
EC	Efficiency category
VSD	Variable Speed Drive
SR	Specific ratio

[m³/h]	Flow rate
[Pa]	Static pressure / Total pressure
[RPM]	Speed

ηe [%]	Efficiency
N	Efficiency grade
[kW]	Input power

Model	MC	EC	VSD	SR	ηe[%]	N	[kW]	[m³/h]	[Pa]	[RPM]
THT/WALL-A/B-40-2T-1-F-400 IE3	A	Statisk	VFD ikke nødvendig	1.00	42.0	48.5	0.923	4420	316	2879
THT/WALL-A/B-40-2T-1.5-F-400 IE3	A	Statisk	VFD ikke nødvendig	1.00	38.0	43.6	1.280	5180	338	2902
THT/WALL-A/B-45-2T-2-F-400 IE3	A	Statisk	VFD ikke nødvendig	1.00	39.3	44.5	1.542	6802	321	2939
THT/WALL-A/B-45-2T-3-F-400 IE3	A	Statisk	VFD ikke nødvendig	1.01	38.8	42.8	2.338	8144	401	2917
THT/WALL-A/B-50-2T-4-F-400 IE3	A	Statisk	VFD ikke nødvendig	1.01	35.4	38.5	3.293	9218	455	2913
THT/WALL-A/B-56-2T-5.5-F-400 IE3	A	Statisk	VFD ikke nødvendig	1.01	46.5	49.0	4.106	12896	533	2954
THT/WALL-A/B-56-2T-7.5-F-400 IE3	A	Statisk	VFD ikke nødvendig	1.00	41.7	48.8	0.748	7959	141	2995
THT/WALL-A-63-4T-3-F-400 IE3	C	Statisk	VFD ikke nødvendig	1.00	34.3	38.2	2.449	14917	203	1466
THT/WALL-A-63-4T-4-F-400 IE3	B	Total	VFD ikke nødvendig	1.00	64.2	67.6	2.935	24239	280	1460
THT/WALL-A-63-6T-1-F-400 IE3	B	Total	VFD ikke nødvendig	1.00	57.6	64.2	0.920	15881	120	951
THT/WALL-A-71-4T-3-F-400 IE3	C	Statisk	VFD ikke nødvendig	1.00	44.2	48.2	2.297	17056	214	1468
THT/WALL-A-71-4T-4-F-400 IE3	C	Statisk	VFD ikke nødvendig	1.00	41.9	45.3	2.893	19369	225	1461
THT/WALL-A-71-4T-5.5-F-400 IE3	B	Total	VFD ikke nødvendig	1.00	64.5	66.7	4.390	29880	341	1450
THT/WALL-A-71-6T-1.5-F-400 IE3	C	Statisk	VFD ikke nødvendig	1.00	33.9	40.0	1.107	14226	95	958
THT/WALL-A-80-4T-3-F-400 IE3	C	Statisk	VFD ikke nødvendig	1.00	48.6	52.6	2.344	16923	242	1468
THT/WALL-A-80-4T-4-F-400 IE3	C	Statisk	VFD ikke nødvendig	1.00	45.8	48.8	3.309	20444	267	1455
THT/WALL-A-80-4T-5.5-F-400 IE3	C	Statisk	VFD ikke nødvendig	1.00	44.8	47.4	3.902	22304	282	1456
THT/WALL-A-80-4T-7.5-F-400 IE3	C	Statisk	VFD ikke nødvendig	1.00	43.2	44.8	5.700	26826	330	1467
THT/WALL-A-80-6T-1.5-F-400 IE3	C	Statisk	VFD ikke nødvendig	1.00	40.8	46.6	1.206	14613	121	955
THT/WALL-A-80-6T-2-F-400 IE3	C	Statisk	VFD ikke nødvendig	1.00	39.8	44.7	1.738	17576	142	956
THT/WALL-A-90-4T-7.5-F-400 IE3	C	Statisk	VFD ikke nødvendig	1.00	49.0	50.4	6.089	31521	340	1465
THT/WALL-A-90-4T-10-F-400 IE3	C	Statisk	VFD ikke nødvendig	1.01	45.9	46.6	7.761	35009	366	1477
THT/WALL-A-90-4T-15-F-400 IE3	C	Statisk	VFD ikke nødvendig	1.01	40.6	40.6	11.623	41490	409	1481
THT/WALL-A-90-6T-3-F-400 IE3	C	Statisk	VFD ikke nødvendig	1.00	41.5	45.3	2.593	23753	163	960
THT/WALL-A-90-6T-4-F-400 IE3	C	Statisk	VFD ikke nødvendig	1.00	38.4	41.3	3.459	27183	176	970
THT/WALL-A-100-4T-10-F-400 IE3	C	Statisk	VFD ikke nødvendig	1.00	48.7	49.3	8.144	37591	380	1476
THT/WALL-A-100-4T-15-F-400 IE3	C	Statisk	VFD ikke nødvendig	1.01	44.6	44.5	11.891	44571	428	1480
THT/WALL-A-100-4T-20-F-400 IE3	C	Statisk	VFD ikke nødvendig	1.01	40.7	40.4	15.945	50259	465	1485
THT/WALL-A-100-6T-5.5-F-400 IE3	C	Statisk	VFD ikke nødvendig	1.00	39.4	41.7	4.377	32373	192	971
THT/WALL-A-100-6T-7.5-F-400 IE3	B	Total	VFD ikke nødvendig	1.00	62.1	63.9	5.237	53520	215	975
THT/WALL-B-63-4T-3-F-400 IE3	C	Statisk	VFD ikke nødvendig	1.00	34.3	38.2	2.449	14917	203	1466
THT/WALL-B-63-4T-4-F-400 IE3	B	Total	VFD ikke nødvendig	1.00	64.2	67.6	2.935	24239	280	1460
THT/WALL-B-63-6T-1-F-400 IE3	B	Total	VFD ikke nødvendig	1.00	57.6	64.2	0.920	15881	120	951
THT/WALL-B-71-4T-3-F-400 IE3	C	Statisk	VFD ikke nødvendig	1.00	44.2	48.2	2.297	17056	214	1468
THT/WALL-B-71-4T-4-F-400 IE3	C	Statisk	VFD ikke nødvendig	1.00	41.9	45.3	2.893	19369	225	1461
THT/WALL-B-71-4T-5.5-F-400 IE3	B	Total	VFD ikke nødvendig	1.00	64.5	66.7	4.390	29880	341	1450
THT/WALL-B-71-6T-1.5-F-400 IE3	C	Statisk	VFD ikke nødvendig	1.00	33.9	40.0	1.107	14226	95	958
THT/WALL-B-80-4T-3-F-400 IE3	C	Statisk	VFD ikke nødvendig	1.00	48.6	52.6	2.344	16923	242	1468
THT/WALL-B-80-4T-4-F-400 IE3	C	Statisk	VFD ikke nødvendig	1.00	45.8	48.8	3.309	20444	267	1455
THT/WALL-B-80-4T-5.5-F-400 IE3	C	Statisk	VFD ikke nødvendig	1.00	44.8	47.4	3.902	22304	282	1456
THT/WALL-B-80-4T-7.5-F-400 IE3	C	Statisk	VFD ikke nødvendig	1.00	43.2	44.8	5.700	26826	330	1467
THT/WALL-B-80-6T-1.5-F-400 IE3	C	Statisk	VFD ikke nødvendig	1.00	40.8	46.6	1.206	14613	121	955
THT/WALL-B-80-6T-2-F-400 IE3	C	Statisk	VFD ikke nødvendig	1.00	39.8	44.7	1.738	17576	142	956
THT/WALL-B-90-4T-7.5-F-400 IE3	C	Statisk	VFD ikke nødvendig	1.00	49.0	50.4	6.089	31521	340	1465
THT/WALL-B-90-4T-10-F-400 IE3	C	Statisk	VFD ikke nødvendig	1.01	45.9	46.6	7.761	35009	366	1477
THT/WALL-B-90-4T-15-F-400 IE3	C	Statisk	VFD ikke nødvendig	1.01	40.6	40.6	11.623	41490	409	1481
THT/WALL-B-90-6T-3-F-400 IE3	C	Statisk	VFD ikke nødvendig	1.00	41.5	45.3	2.593	23753	163	960
THT/WALL-B-90-6T-4-F-400 IE3	C	Statisk	VFD ikke nødvendig	1.00	38.4	41.3	3.459	27183	176	970
THT/WALL-B-100-4T-10-F-400 IE3	C	Statisk	VFD ikke nødvendig	1.00	48.7	49.3	8.144	37591	380	1476
THT/WALL-B-100-4T-15-F-400 IE3	C	Statisk	VFD ikke nødvendig	1.01	44.6	44.5	11.891	44571	428	1480
THT/WALL-B-100-4T-20-F-400 IE3	C	Statisk	VFD ikke nødvendig	1.01	40.7	40.4	15.945	50259	465	1485
THT/WALL-B-100-6T-5.5-F-400 IE3	C	Statisk	VFD ikke nødvendig	1.00	39.4	41.7	4.377	32373	192	971
THT/WALL-B-100-6T-7.5-F-400 IE3	B	Total	VFD ikke nødvendig	1.00	62.1	63.9	5.237	53520	215	975
THT/WALL-A/B-40-2T-1-F-300 IE3	A	Statisk	VFD ikke nødvendig	1.00	42.0	48.5	0.923	4420	316	2879
THT/WALL-A/B-40-2T-1.5-F-300 IE3	A	Statisk	VFD ikke nødvendig	1.00	38.0	43.6	1.280	5180	338	2902
THT/WALL-A/B-45-2T-2-F-300 IE3	A	Statisk	VFD ikke nødvendig	1.00	39.3	44.5	1.542	6802	321	2939
THT/WALL-A/B-45-2T-3-F-300 IE3	A	Statisk	VFD ikke nødvendig	1.01	38.8	42.8	2.338	8144	401	2917
THT/WALL-A/B-50-2T-4-F-300 IE3	A	Statisk	VFD ikke nødvendig	1.01	35.4	38.5	3.293	9218	455	2913
THT/WALL-A/B-56-2T-5.5-F-300 IE3	A	Statisk	VFD ikke nødvendig	1.01	46.5	49.0	4.106	12896	533	2954

Model	MC	EC	VSD	SR	ηe[%]	N	[kW]	[m³/h]	[Pa]	[RPM]
THT/WALL-A-B-56-2T-7.5-F-300 IE3	A	Statisk	VFD ikke nødvendig	1.00	41.7	48.8	0.748	7959	141	2995
THT/WALL-A-63-4T-3-F-300 IE3	C	Statisk	VFD ikke nødvendig	1.00	34.3	38.2	2.449	14917	203	1466
THT/WALL-A-63-4T-4-F-300 IE3	B	Total	VFD ikke nødvendig	1.00	64.2	67.6	2.935	24239	280	1460
THT/WALL-A-63-6T-1-F-300 IE3	B	Total	VFD ikke nødvendig	1.00	57.6	64.2	0.920	15881	120	951
THT/WALL-A-71-4T-3-F-300 IE3	C	Statisk	VFD ikke nødvendig	1.00	44.2	48.2	2.297	17056	214	1468
THT/WALL-A-71-4T-4-F-300 IE3	C	Statisk	VFD ikke nødvendig	1.00	41.9	45.3	2.893	19369	225	1461
THT/WALL-A-71-4T-5.5-F-300 IE3	B	Total	VFD ikke nødvendig	1.00	64.5	66.7	4.390	29880	341	1450
THT/WALL-A-71-6T-1.5-F-300 IE3	C	Statisk	VFD ikke nødvendig	1.00	33.9	40.0	1.107	14226	95	958
THT/WALL-A-80-4T-3-F-300 IE3	C	Statisk	VFD ikke nødvendig	1.00	48.6	52.6	2.344	16923	242	1468
THT/WALL-A-80-4T-4-F-300 IE3	C	Statisk	VFD ikke nødvendig	1.00	45.8	48.8	3.309	20444	267	1455
THT/WALL-A-80-4T-5.5-F-300 IE3	C	Statisk	VFD ikke nødvendig	1.00	44.8	47.4	3.902	22304	282	1456
THT/WALL-A-80-4T-7.5-F-300 IE3	C	Statisk	VFD ikke nødvendig	1.00	43.2	44.8	5.700	26826	330	1467
THT/WALL-A-80-6T-1.5-F-300 IE3	C	Statisk	VFD ikke nødvendig	1.00	40.8	46.6	1.206	14613	121	955
THT/WALL-A-80-6T-2-F-300 IE3	C	Statisk	VFD ikke nødvendig	1.00	39.8	44.7	1.738	17576	142	956
THT/WALL-A-90-4T-7.5-F-300 IE3	C	Statisk	VFD ikke nødvendig	1.00	49.0	50.4	6.089	31521	340	1465
THT/WALL-A-90-4T-10-F-300 IE3	C	Statisk	VFD ikke nødvendig	1.01	45.9	46.6	7.761	35009	366	1477
THT/WALL-A-90-4T-15-F-300 IE3	C	Statisk	VFD ikke nødvendig	1.01	40.6	40.6	11.623	41490	409	1481
THT/WALL-A-90-6T-3-F-300 IE3	C	Statisk	VFD ikke nødvendig	1.00	41.5	45.3	2.593	23753	163	960
THT/WALL-A-90-6T-4-F-300 IE3	C	Statisk	VFD ikke nødvendig	1.00	38.4	41.3	3.459	27183	176	970
THT/WALL-A-100-4T-10-F-300 IE3	C	Statisk	VFD ikke nødvendig	1.00	48.7	49.3	8.144	37591	380	1476
THT/WALL-A-100-4T-15-F-300 IE3	C	Statisk	VFD ikke nødvendig	1.01	44.6	44.5	11.891	44571	428	1480
THT/WALL-A-100-4T-20-F-300 IE3	C	Statisk	VFD ikke nødvendig	1.01	40.7	40.4	15.945	50259	465	1485
THT/WALL-A-100-6T-5.5-F-300 IE3	C	Statisk	VFD ikke nødvendig	1.00	39.4	41.7	4.377	32373	192	971
THT/WALL-A-100-6T-7.5-F-300 IE3	B	Total	VFD ikke nødvendig	1.00	62.1	63.9	5.237	53520	215	975
THT/WALL-B-63-4T-4-F-300 IE3	B	Total	VFD ikke nødvendig	1.00	64.2	67.6	2.935	24239	280	1460
THT/WALL-B-63-6T-1-F-300 IE3	B	Total	VFD ikke nødvendig	1.00	57.6	64.2	0.920	15881	120	951
THT/WALL-B-71-4T-3-F-300 IE3	C	Statisk	VFD ikke nødvendig	1.00	44.2	48.2	2.297	17056	214	1468
THT/WALL-B-71-4T-4-F-300 IE3	C	Statisk	VFD ikke nødvendig	1.00	41.9	45.3	2.893	19369	225	1461
THT/WALL-B-71-4T-5.5-F-300 IE3	B	Total	VFD ikke nødvendig	1.00	64.5	66.7	4.390	29880	341	1450
THT/WALL-B-71-6T-1.5-F-300 IE3	C	Statisk	VFD ikke nødvendig	1.00	33.9	40.0	1.107	14226	95	958
THT/WALL-B-80-4T-3-F-300 IE3	C	Statisk	VFD ikke nødvendig	1.00	48.6	52.6	2.344	16923	242	1468
THT/WALL-B-80-4T-4-F-300 IE3	C	Statisk	VFD ikke nødvendig	1.00	45.8	48.8	3.309	20444	267	1455
THT/WALL-B-80-4T-5.5-F-300 IE3	C	Statisk	VFD ikke nødvendig	1.00	44.8	47.4	3.902	22304	282	1456
THT/WALL-B-80-4T-7.5-F-300 IE3	C	Statisk	VFD ikke nødvendig	1.00	43.2	44.8	5.700	26826	330	1467
THT/WALL-B-80-6T-1.5-F-300 IE3	C	Statisk	VFD ikke nødvendig	1.00	40.8	46.6	1.206	14613	121	955
THT/WALL-B-80-6T-2-F-300 IE3	C	Statisk	VFD ikke nødvendig	1.00	39.8	44.7	1.738	17576	142	956
THT/WALL-B-90-4T-7.5-F-300 IE3	C	Statisk	VFD ikke nødvendig	1.00	49.0	50.4	6.089	31521	340	1465
THT/WALL-B-90-4T-10-F-300 IE3	C	Statisk	VFD ikke nødvendig	1.01	45.9	46.6	7.761	35009	366	1477
THT/WALL-B-90-4T-15-F-300 IE3	C	Statisk	VFD ikke nødvendig	1.01	40.6	40.6	11.623	41490	409	1481
THT/WALL-B-90-6T-3-F-300 IE3	C	Statisk	VFD ikke nødvendig	1.00	41.5	45.3	2.593	23753	163	960
THT/WALL-B-90-6T-4-F-300 IE3	C	Statisk	VFD ikke nødvendig	1.00	38.4	41.3	3.459	27183	176	970
THT/WALL-B-100-4T-10-F-300 IE3	C	Statisk	VFD ikke nødvendig	1.00	48.7	49.3	8.144	37591	380	1476
THT/WALL-B-100-4T-15-F-300 IE3	C	Statisk	VFD ikke nødvendig	1.01	44.6	44.5	11.891	44571	428	1480
THT/WALL-B-100-4T-20-F-300 IE3	C	Statisk	VFD ikke nødvendig	1.01	40.7	40.4	15.945	50259	465	1485
THT/WALL-B-100-6T-5.5-F-300 IE3	C	Statisk	VFD ikke nødvendig	1.00	39.4	41.7	4.377	32373	192	971
THT/WALL-B-100-6T-7.5-F-300 IE3	B	Total	VFD ikke nødvendig	1.00	62.1	63.9	5.237	53520	215	975